



**Fair
Trading**

Certificate of Suitability Non-Declared Article

Certificate Number: **CS10326N**

This is to certify that the article specified below is accepted by NSW FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS/NZS 3000 and subject to the conditions stated.

Issued to:	SMA Australia Pty Ltd	
Article:	Grid connected inverter + Multigate console system for use with photovoltaic systems, Class I, IP65 inverter and IP20 Multigate console. DC Input for single inverter: Max voltage 45V; MPPT range 23-32V; Max current 8.5A; Max power 230W; AC Output for Multigate console: Max voltage 270V; Rated voltage range 184-230V; Frequency 50Hz; Max power 2760W; Rated current 12A.	
Trade Name or Mark:	SUNNY BOY 240 + SUNNY MULTIGATE	
Ratings:	Volts: Watts:	Amperes: Hertz:
	Other Name Plate Particulars:	
Type Reference Code:	SB240-10 + MULTIGATE-10	
Examined for Compliance With:	AS/NZS 4777.2:2005 + AS/NZS 4777.3:2005 + AS/NZS 3100:2009+A1-2	
Nominated Marking:	CS10326N or approved alternate mark	
Date of Approval:	13/05/2014	
Approval Expires:	13/05/2019 unless suspended, cancelled, renewed or extended	

Conditions:

1. This certification will be withdrawn automatically if an article of this type is declared pursuant to the Electricity (Consumer Safety) Act, 2004.
2. This certificate is issued subject to the article and approved variations being maintained at the standard of the article examined at the time of approval.



On behalf of the Commissioner for Fair Trading

For current information regarding currency of certificate, refer to the Fair Trading Website