



**BUREAU
VERITAS**

Certificate of compliance

Applicant: SMA Solar Technology AG
Sonnenallee 1
34266 Niestetal
Germany

Product: Automatic disconnection device between a generator and the public low-voltage grid

Model: SB1.5-1VL-40
SB2.5-1VL-40

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with EN 50438:2007 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

EN 50438:2007,
Requirements for the connection of micro-generators in parallel with the public low-voltage distribution networks.

The following parameters according to EN 50438:2007 were applied.

Default interface protection settings:

| | |
|---------------------------|--------|
| Under voltage limit: | 195,5V |
| Upper voltage limit: | 264,5V |
| Under frequency limit: | 47,0Hz |
| Upper frequency limit: | 51,0Hz |
| 10-min-value to EN 50160: | 253V |

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 14TH0397-EN50438
Certificate number: U15-101
Date of issue: 2015-04-08

Certification body

Dieter Zitzmann



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to EN 45011 - ISO / IEC Guide 65