



Manufacturer's Declaration

Confirmation of Compliance with the Requirements of C 10/11:2012

We hereby confirm the compliance with the requirements of C 10/11:2012 for all SMA inverters listed in the following table as of the respective firmware version with setting according to C 10/11:2012.

Inverter Family	From firmware version
SB1.5-1VL-40 / SB2.5-1VL-40	2.00
SBS2.5-1VL-10	2.02
SB3.0-1AV-40 / SB3.6-1AV-40 / SB4.0-1AV-40 / SB5.0-1AV-40	1.01
SB 3000TL-21 / SB 4000TL-21 / SB 5000TL-21	1.50
SB 3600TL-21	2.10
SB 3600SE-10 / SB 5000SE-10	2.04
STP 5000TL-20 / STP 6000TL-20 / STP 7000TL-20 / STP 8000TL-20 / STP 9000TL-20	2.01
STP 10000TL-20 / STP 12000TL-20	2.52
STP 15000TL-10	2.31
STP 15000TL-30 / STP 17000TL-30	1.02
STP 20000TL-30 / STP 25000TL-30	1.00
STP 50-40	1.01
STP 60-10*	1.60

* The C 10/11:2012 requires an external protection device with islanding detection for PV plants with a power above 10 kVA.

The compliance with VDE 0126-1-1 by an accredited institute, as required in annex 4, and the compliance with the VDE-AR N-4105 are available at www.SMA-Solar.com.

Niestetal, 09.07.2017

SMA Solar Technology AG

A handwritten signature in black ink, appearing to read 'ppa. Johannes Kneip', is written over a light blue horizontal line.

ppa. Dr.-Ing. Johannes Kneip
EVP Development Center