



**BUREAU  
VERITAS**

# Certificate of compliance

**Applicant:** SMA Solar Technology AG  
Sonnenallee 1  
34266 Niestetal  
Germany

**Product:** Photovoltaic (PV) inverter

**Model:** STP 8000TL-10  
STP 10000TL-10  
STP 12000TL-10  
STP 15000TL-10  
STP 15000TLHE-10  
STP 15000TLEE-10  
STP 17000TL-10  
STP 20000TLHE-10  
STP 20000TLEE-10

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

## Applied rules and standards:

### NRS 097-2-1:2010 ed1.0

Grid interconnection of embedded generation  
Part 2: Small-scale embedded generation  
Section 1: Utility interface

### IEC 61727:2004 ed2.0

Photovoltaic (PV) systems – Characteristics of the utility interface

### IEC 62116:2008 ed1.0

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

### DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and parallel to the public low voltage network

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** 10TH0052-NRS 097-2-1

**Certificate number:** U15-0245

**Date of issue:** 2015-07-08

## Certification body

Dieter Zitzmann



Deutsche  
Akkreditierungsstelle  
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH  
Accredited according to EN 45011 - ISO / IEC Guide 65