



Manufacturer's Declaration

Romanian Technical Standard: Technical Conditions for Connection of the Photovoltaic Power Plants to Public Electrical Grids

SMA hereby declares that the inverters listed in the table below are equipped with a "Grid Failure" detection function to prevent stand-alone grids. The inverters comply with the requirements for PV plants up to 400 kW specified in chapter 15 of the Technical Standard: Technical Conditions for the Connection of Photovoltaic Power Plants to the Utility Grid published under "Official Gazette of Romania, Part I, No. 312/30.05.2013" by ANRE (National Regulatory Authority in the field of Energy).

SUNNY BOY	SUNNY TRIPOWER
without transformer	without transformer
SB 3000TL-21	STP 10000TL-10
SB 3600TL-21	STP 12000TL-10
SB 4000TL-21	STP 15000TL-10
SB 5000TL-21	STP 17000TL-10
SB 6000TL-21	STP 15000TLEE-10
SB 2500TLST-21	STP 20000TLEE-10
SB 3000TLST-21	STP 5000TL-20
SB 2000HF-30	STP 6000TL-20
SB 2500HF-30	STP 7000TL-20
SB 3000HF-30	STP 8000TL-20
	STP 9000TL-20
	STP 10000TL-20
	STP 12000TL-20
	STP 20000TL-30
	STP 25000TL-30

Niestetal, 12. September 2014

SMA Solar Technology AG

ppa Frank Greizer
 (Vice President MPTPD)