

**SMA Solar Technology AG**

Sonnenallee 1
 34266 Niestetal
 GERMANY
 Tel.: +49 561 9522-0
 Fax: +49 561 9522-100
 E-Mail: info@SMA.de
 Internet: www.SMA.de

SMA Solar Technology AG · Sonnenallee 1 · 34266 Niestetal · GERMANY

To whom it may concern

Author Thomas Weiss
 Phone +49 561 9522- 4755
 Fax +49 561 9522- 100
 E-Mail thomas.weiss@sma.de
 Date 05.08.2020

**Medium Voltage Grid Connection in Italy
 MVPS Compliance according to CEI 0-16**

Hereby we confirm that our Medium Voltage Power Station (MVPS) for PV applications with Sunny Central (SC or SC UP) is compliant to the Italian standard CEI 0-16. According paragraph 8.5.13 of this standard there is a limit on 20 KV grid for Medium Voltage Transformer (MVT), defined with a transformer power of 2000 KVA and a short circuit voltage Vcc of 6%. Higher power classes are allowed in case of using higher short circuit impedances, to reduce the short circuit power according to paragraph 8.5.13. SMA will deliver the following transformers for 20 KV grid connection:

MVPS	DC Voltage	MVT power	AC Voltage	Vcc
2200	1000 V	2000 KVA	20 KV	>6 %
2475	1000 V	2250 KVA	20 KV	>6.75 %
2660	1500 V	2394 KVA	20 KV	>7.18 %
2800	1500 V	2520 KVA	20 KV	>7.56 %
2930	1500 V	2637 KVA	20 KV	>7.91 %
3060	1500 V	2754 KVA	20 KV	>8.26 %

There is also a limit for the maximum power of 6000 KVA that can be energized at the same time according to paragraph 8.5.14 of the standard CEI 0-16. In this case SMA Solar Technology AG can offer the option Cascade Control for a delayed switching of the MV transformers, to reduce the inrush current.

Yours sincerely,

SMA Solar Technology AG

i. V. Carsten Wendt

Head of PM Central Power Conversion
 BU Large Scale & Project Solutions

i. A. Thomas Weiss

Product Manager Medium Voltage
 BU Large Scale & Project Solutions