

Certificate Number: AZ 69025885

Page: 0024



CERTIFICATE OF APPROVAL

Authorised marking: TUV-025885-EA

CONTINUATION SHEET 23

(Modification 6)

Add alternative inverters:

Classified as:

Installed within power conditioning equipment (PCE), enclosed outdoor, suitable for installation exposed to sunlight as per AS/NZS 5033.

Switch arrangement: XBHP+3619-ADS/6, 6 layers

Installed within Solar Inverter

lthe Solar at 40°C: 50A, lthe Solar at 60°C: 50A

Brand: SMA

Models: STP 12-50, STP 15-50, STP 20-50, STP 25-50

Size: 728mm×762mm×266mm (W x H x D)

Enclosure material: Aluminum alloy.

Issue Date: 26/06/2023

Expiry Date: 23/03/2027

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



www.jas-anz.org/register