



SMA STRING-MONITOR

SSM-U-1610 / SSM-U-2410 / SSM-U-3210

SSM-U-1615 / SSM-U-2415 / SSM-U-3215

Project name:

Customer:

Address, location of the system:

Product serial number

Product production version

i Content of the maintenance report

In conjunction with the other product documentation, the maintenance report assures faultless operation of the product and peripheral devices from SMA Solar Technology AG. Maintenance work does not automatically guarantee electrical safety.

The maintenance report documents the maintenance work performed at the recommended maintenance intervals.

i Storage of the maintenance report

- After maintenance work, keep the maintenance report at hand near the product.
- In addition, a copy is to be sent to maintenance.service@sma.de at the latest four weeks after completion of the maintenance work. Enter the serial number of the product on which maintenance was carried out in the subject line.

i Maintenance instructions

- All work must only be carried out in accordance with this product's operating manual. All safety information must be observed.

No.	Appendix

1 Maintenance Activities

Maintenance with DC voltage present

Task	Interval	Date completed
Check DC load-break switch.	24 months	

Maintenance under voltage-free conditions

Task	Interval	Date completed
Check protective covers.	24 months	
Perform visual inspection.	24 months	
Check condensate drain.	24 months	
Check vent plug.	24 months	
Check the seals.	24 months	
Check the labels.	24 months	
Check LEDs.	24 months	
Check bolted, clamp and plug connections.	24 months	
Check the inline fuse connectors*.	24 months	
Check ground connection.	24 months	

* available as an accessory

Your signature confirms that the work listed above has been carried out.

Customer or contractor company*	Last name, first name*	Date	Signature
---------------------------------	------------------------	------	-----------

* in block letters