



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-202733-EA

Certificate Holder: SMA Australia Pty Ltd
Level 1, 213 Miller St
North Sydney NSW 2060
Australia

Regulatory Definition: DC Isolator
Product Description: DC Isolator for use inside inverter
Trade Name/s: SMA
Model No.: SB1.5-1VL-40 (PV Switch Disconnecter)
Rating/Marking/s: Utilization Category DC-PV2, Ue:600V
Ie:10A
Imake:18A,
Ic(break):18A,
Isolar the 60°C: 18A
IP65

Standard/s: AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-202733-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 7 December 2020

Expiry Date: 7 December 2025

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 07-12-20 202733/1