



A P P R O V A L S ®

# Certificate of Conformity/Approval

## \*Addendum\*

**Certificate No.:** SAA-202733-EA

**Date of Issue:** 7 December 2020

**Regulatory Definition:** DC Isolator

**Product Description:** DC Isolator for use inside inverter

Additional Models	Trade Name	Rating/Marking
SB6.0-1AV-41 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:600V Ie:15A Imake:20A, Ic(break):20A, Isolar the 60°C: 30A IP65
STP3.0-3AV-40 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:850V Ie:12A Imake:18A, Ic(break):18A, Isolar the 60°C: 18A IP65
STP4.0-3AV-40 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:850V Ie:12A Imake:18A, Ic(break):18A, Isolar the 60°C: 18A IP65
STP5.0-3AV-40 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:850V Ie:12A Imake:18A, Ic(break):18A, Isolar the 60°C: 18A IP65

*R. A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 08-12-20 202733/3a  
Rating/Marking corrected