



A P P R O V A L S ®

Certificate of Conformity/Approval

Addendum

Certificate No.: SAA-202733-EA

Date of Issue: 7 December 2020

Regulatory Definition: DC Isolator

Product Description: DC Isolator for use inside inverter

Additional Models	Trade Name	Rating/Marking
STP20000TL-30 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:1000V Ie:33A Imake:43A, Ic(break):43A, Isolar the 60°C: 43A IP65
STP25000TL-30 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:1000V Ie:33A Imake:43A, Ic(break):43A, Isolar the 60°C: 43A IP65
STP50-40 (PV Switch Disconnecter)	SMA	Utilization Category DC-PV2, Ue:1000V Ie:20A Imake:30A, Ic(break):30A, Isolar the 60°C: 30A IP65

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 08-12-20 202733/5a
Rating/Marking corrected